

Permit	Imposed Date	Facility	Owner	Region	County	Reason	Explanation
NC0031879	03/01/2007	Corpening Creek WWTP	City of Marion	Asheville	McDowell	Under SOC	BOD, TSS, CN, TRC violations
NC0039578	12/06/2006	Jackson County WWTP	Tuckaseegee Water & Sewer Authority	Asheville	Jackson	Under SOC	BOD, Fecal, TSS violations
NC0071200	08/08/2007	Catawba River WWTP	City of Marion	Asheville	McDowell	Under SOC	BOD, TSS, Fecal violations
WQCS00084	09/01/2007	Brevard Collection System	City of Brevard	Asheville	Transylvania	Under SOC	moratorium and SOC due to frequent and repetitive SSOs on specified sewer line(s)
WQCS00101	01/02/2001	Franklin Collection System	Town of Franklin	Asheville	Macon	Statutory moratorium imposed	moratorium due to frequent and repetitive SSOs on specified sewer line(s)
NC0021610	11/22/2006	Clarkton WWTP	Town of Clarkton	Fayetteville	Bladen	Under SOC	BOD & TSS violations
NC0025577	02/03/2009	Red Springs WWTP	Town of Red Springs	Fayetteville	Robeson	Under SOC	Hg & CN violations
WQCS00073	03/26/2007	Dunn Collection System	City of Dunn	Fayetteville	Harnett	Under SOC	moratorium and SOC due to frequent and repetitive SSOs on specified sewer line(s)
NC0072940	07/16/1998	State Street WWTP	City of High Shoals	Mooresville	Gaston	80% Rule imposed	Annual average flow @ 82.5% in 1997.
NC0020061	11/01/2008	Spring Hope WWTP	Town of Spring Hope	Raleigh	Nash	Under SOC	BOD, TSS, Fecal violations
NC0025437	07/22/2004	Rich Square WWTP	Town of Rich Square	Raleigh	Northampton	90% Rule imposed Under SOC	Annual average flow @ 95.7% in 2003. BOD, NH3, TRC, Fecal violations
NC0035866	04/05/2007	Bynum WWTP	County of Chatham	Raleigh	Chatham	80% Rule imposed	Annual average flow @ 83.15% in 2006.
NC0057606	07/22/2004	Stantonsburg WWTP	Town of Stantonsburg	Raleigh	Wilson	80% Rule imposed	Annual average flow @ 84.6% in 2003.
WQ0002560	07/15/2003	Bailey Wastewater Treatment Plant	Town of Bailey	Raleigh	Nash	Statutory moratorium imposed	excessive I/I
WQ0003405	07/09/1998	Elm City Spray Irrigation WWTP	Town of Elm City	Raleigh	Wilson	Statutory moratorium imposed	excessive I/I
WQ0003299	02/26/2007	Seaboard Town-WWTF/Spray	Town of Seaboard	Raleigh	Northampton	Statutory moratorium imposed	excessive I/I
WQ0023203	07/01/2007	Rich Square WWTP	Town of Rich Square	Raleigh	Northampton	Under SOC	excessive I/I, overloaded sprayfields
WQCS00055	09/01/2007	Henderson Collection System	City of Henderson	Raleigh	Vance	Under SOC	moratorium due to frequent and repetitive SSOs on specified sewer line(s)

NC0020028	07/22/2004	Plymouth WWTP	Town of Plymouth	Washington	Washington	90% Rule imposed	Annual average flow @ 90.9% in 2003.
NC0021342	07/22/2004	Trenton WWTP	Town of Trenton	Washington	Jones	90% Rule imposed; Under SOC	Town is repairing sewer lines, and plans to build a spray irrigation system and eliminate the discharge.
NC0031828	04/17/2006	Vanceboro WWTP	Town of Vanceboro	Washington	Craven	80% Rule imposed	Annual average flow @ 81.4% in 2005.
WQ0002520	07/16/2007	Town of Bath Spray Irrigation Facility	Town of Bath	Washington	Beaufort	Statutory moratorium imposed	Diminished sprayfield conditions, additional sprayfields needed
WQ0003885	09/21/1998	Ahoskie Town-WWTP/Spray	Town of Ahoskie	Washington	Hertford	Under SOC	excessive I/I, overloaded sprayfields
NC0020702	07/22/2004	Wallace WWTP	Town of Wallace	Wilmington	Duplin	80% Rule imposed	Annual average flow @ 88.1% in 2003.
NC0021831	10/01/2004	Beaufort WWTP	Town of Beaufort	Wilmington	Carteret	Under SOC	see entry for WQCS00102
NC0023230	07/22/2004	Richlands WWTP	Onslow Water And Sewer Authority	Wilmington	Onslow	90% Rule imposed/Under SOC	Average annual flow @ 109.8% in 2003. See entry for WQCS00249
NC0026018	05/23/2000	Beulaville WWTP	Town of Beulaville	Wilmington	Duplin	90% Rule imposed	Annual average flow @ 89.24% in 1999; 98.99% in 2006.
NC0049387	07/22/2004	Hunters Creek WWTP	Onslow Water And Sewer Authority	Wilmington	Onslow	80% Rule imposed	Formerly a privately owned facility. Annual average flow @ 88.8% in 2003.
NC0057053	07/22/2004	Springdale Acres WWTP	Onslow Water And Sewer Authority	Wilmington	Onslow	90% Rule imposed; Under SOC	Formerly a privately owned facility. Annual average flow @ 124.9% in 2003. SOC deals with flow and other areas of deficiency.
WQ0009267	09/07/2005	Jacksonville WWTF	City of Jacksonville	Wilmington	Onslow	Under SOC	see entry for WQCS00268
WQCS00102	10/01/2004	Beaufort Collection System	Town of Beaufort	Wilmington	Carteret	Under SOC	moratorium and SOC due to frequent and repetitive SSOs on specified sewer line(s), and also due to extreme high flows at the Beaufort WWTP NC0021831 in excess of WWTP capacity, contributing to NPDES violations.

WQCS00249	06/01/2008	ONWASA Collection System	Onslow Water And Sewer Authority	Wilmington	Carteret	Under SOC	moratorium and SOC due to extreme high flows at the ONWASA Richlands WWTP NC0023230 in excess of WWTP capacity, contributing to NPDES violations.
WQCS00268	09/07/2005	Jacksonville Collection System	City of Jacksonville	Wilmington	Onslow	Under SOC	moratorium and SOC due to continual sewer growth along with Inflow and Infiltration causing Town's high flows in excess of Jacksonville spray field WWTP WQ0009267, contributing to permit violations including inability to maintain required freeboard
WQCS00010	02/01/2006	High Point Collection System	City of High Point	Winston-Salem	Guilford	Under SOC	moratorium and SOC due to frequent and repetitive SSOs on specified sewer line(s)

Updated 12/21/2009

This list is constantly subject to change